

Office of Joint Director
Public Health Institute,
Bengaluru - 560001

Report of Bacteriological analysis of Water Sample

Date: 04/03/2026

Opinion							
Sample No	Source & Particulars of Water Sample	M.P.N. Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
5178	Ground Floor RO	Nic	—	—	SPP	—	—
5179	Second Floor RO	Nic	—	—	SPP	—	—
Principal Poornaprajna Education Centre, No. 42, New Thippas - and 502 HAL 3rd Stage Bloss - 75 Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found							

SECRETARY
POORNAPRAJNA EDUCATION CENTRE
New Thippasandra, HAL 3rd Stage
Bengaluru - 560075

Principal
Poornaprajna Education Centre
New Thippasandra, HAL 3rd Stage
BANGALORE-560 075.

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Bengaluru

(PTO)

Advice:

1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More


SECRETARY
POORNAPRAJNA EDUCATION CENTRE
New Thippasandra, HAL 3rd Stage
Bangalore-560075


PRINCIPAL
Poornaprajna Education Centre
New Thippasandra, H.A.L. 3rd Stage
BANGALORE-560 075.